

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 01

Dated: 26-09-2026

It is certified that an inspection team headed by Dr. Sunil Kumar MO with Pharmacist
Mr. Pradeep Kumar as his helping staff (Name of Officers with designation) from 26/09/2026 PHED enclosed 26/09/26

inspected the **NAND KISHORE VIDYA BHAVAN , DHANUHA, CHAKA , NAINI, PRAYAGRAJ U.P .**

211008 (Name & Address of the school) on 25/9/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing 25/09/26 dated Prayagraj Jal Kal Vibhag

Laboratory, Chemical Analysis (PHED Lab) certified that the **NAND KISHORE VIDYA BHAVAN** has safe drinking water facilities for the students and members of staff of the institution.

School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: [Signature]
Name : [Signature]
Designation : 26/9/26
Name & Address of the Office / Department : [Signature]

To
NAND KISHORE VIDYA BHAVAN
DHANUHA CHAKA NAINI PRAYAGRAJ
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



PRAYAGRAJ JAL KAL VIBHAG LABORATORY

CHEMICAL ANALYSIS OF WATER

Test Report

Sl. NO

1. Source of sample *Namal kishore vidya Bhawan Dhamua, Rana Road Prayagraj*
2. Date of Sampling *25/09/26*
3. Date of Analysis *25/09/26*

Physico Chemical Parameter	BIS Limits IS 10500 : 2012		Result of test
	Requirement (Desirable Limit) Mg/l	Permissible limit In the absence of Alternate source Mg/l	
4. Total Dissolved solids	500	2000	<i>429</i>
5. Hardness Total as CaCO ₃	200	600	<i>310</i>
6. Hardness Temporary as CaCO ₃	NS	NS	<i>—</i>
7. Hardness Permanent as CaCO ₃	NS	NS	<i>—</i>
8. Chlorine as Chlorides Cl	250	1000	<i>74</i>
9. Total Alkalinity as CaCO ₃	200	600	<i>272</i>
10. Nitrites as NO ₂	NS	NS	<i>—</i>
11. Nitrate as NO ₃	45	No relaxation	<i>160</i>
12. Iron as Fe	0.3	No relaxation	<i>—</i>
13. Fluoride as F	1.0	1.5	<i>0.3</i>
14. Colour Hazen Unit	5	15	<i>Nil</i>
15. Taste	Agreeable	Agreeable	<i>Agreeable</i>
16. Odour	Agreeable	Agreeable	<i>Agreeable</i>
17. pH Value	6.5 to 8.5	No relaxation	<i>7.2</i>
18. Conductivity	NS	NS	<i>792</i>
19. Turbidity NTU	1	5	<i>0.3</i>
20. Calcium as Ca	75	200	<i>—</i>
21. Magnesium as Mg	30	100	<i>—</i>
22. Free Residual Chlorine	0.2	NS	<i>—</i>

NS=Not Specified

Remarks

(Based on above test water sample found suitable for drinking purpose)

Chemist

E.E.

Copy forwarded for information to

1. The addl. Director, State Health Institute, Sector-C, Chetan Bihar, Aliganj, Lucknow, U.P.
2. Chief Medical Officer, Prayagraj.
3. Mukhya Nagar Swasthya Adhikari, Nagar Nigam. Prayagraj.
4. Nagar Ayukta, Nigar Nigam, Prayagraj.
5. The Suprintending Engineer (R&D) office of Addl. Chief Engineer (PPR&D), U.P. Jal Nigam, 6 Rana Pratap marg, Lucknow.
6. Chairman, jalkal Vibhag/Mayor, Nigam, Prayagraj.

E.E.